

O'Brien Enterprises

2420 E. 28th Street, Unit 2
Signal Hill, California 90755
Tel: 562-988-9546

Email: sobrienenterprises@gmail.com
F.A.A. # QK3R792L

WORK ORDER NO. 24951

INSPECTION AND TEARDOWN REPORT

Customer Pius Parts Date Received 10-22-2024
Address 11 Bee Tree Circle Units Received this P.O. 1
Rockport TX 78382 Unit 1 of 1 Units
Customer P.O. # 0051 Assembly Serial # 28999 C1
Part Number 33500026-1 Cylinder Serial # _____
Other Part Number N/A Other: _____
Manufacturer: Kidde HTL/PacSci AMEREX Other _____
Description: Fire Extinguisher Other _____

CUSTOMER REQUESTS

Overhaul Weight and Leak Test
Hydrostatic Test Inspect interior
Repair Other _____
Refill _____
Inspect and test pressure switch Yes No N/A

INITIAL INSPECTION

Date of Mfg. 10-2009 DOT Rating: 4D _____ 7945- 975 Other _____
Last Overhaul 10-2009 Capacity: 60 C.I. 86 C.I. 90 C.I. 125 C.I.
#1 Cartridge Date: _____ / _____ None 195 C.I. 224 C.I. Other Cap. 65 C.I.
#2 Cartridge Date: _____ / _____ None Test P.S.I. 1600 1800 2000 2100 2400 3000 Other 2270
#3 Cartridge Date: _____ / _____ None Received: Full Empty Fired Low P.S.I.

INITIAL INSPECTION ANALYSIS

Parts Missing: None Cartridge(s) Discharge Outlet(s) Safety Cap(s) Halon/N2 Other: _____
Additional Parts Received: None Safety Caps Strap/Clamp Other _____
Exterior Condition: Good Fair Poor Other _____
Interior Inspection: Pass Fail Hidden Damage: Yes No Comment _____
Repairable: Yes No BER/Scrap: Yes No
Serviced per Mfg: HTL/PacSci Kidde NFPA10 Other _____
Serviced I.A.W. Customer Procedures Manual: Yes No Manual # 26-22-58 Rev. Date 03-2023
Other _____ Rev. # _____
Investigate A.D. Activity: Yes No By Sid O Findings: No Activity Other: _____

CORRECTIVE ACTIONS

Overhauled IAW Mfg Specs Inspect Interior Scope of Work: Inspect and test pressure switch Yes No N/A
Repaired IAW Mfg Specs Refinish Exterior
Recharge - Wt. and/or Leak Test No Work Done
Hydrostatic Test IAW DOT/CFR49, PART 180.2

O'Brien Ent., Inc.

SIGNAL HILL, CA 90755

FAA APPROVED

Repair Station # QK3R792L

(562) 988-9546

P/N **33500026-1**

S/N **28999C1**

HYDRO DATE

10-2024

CHARGE DATE WEIGHT

10-21-24

7.99

INSPECT DATE

WEIGHT

WT LESS VALVE(S) & CARTRIDGE(S)

WT WITH VALVE(S) & CARTRIDGE(S)

PACIFIC® HTL/Kin-Tech
SCIENTIFIC Division
FSCM 05167

FIRE EXTINGUISHER

HTL P/N
SERIAL NO.
AGENT(CBrF₃)
PRESSURE

33500026-1 REV.E

28999C1

3.98

LB NOM

800

PSIG @ 70 °F

HTL SPEC. NO.: 170-PSP-004

CHARGE DATE GROSS WT LBS

CHARGE DATE	GROSS WT	LBS
10-28-09	8.85	
10-16-24	9.10	7.99

PAT NO 3,552,495

PAT. NO. 3,129,765

WITH WITHOUT
CARTRIDGE
& OUTLETS

NEXT HYDRO DUE

YEAR

2029

MO

10

OBRIEN ENTERPRISES

Signal Hill, CA

562-988-9546